

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು  
ನಿಗಮ ನಿಯಮಿತ  
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)  
ನಿಗಮ ಕಾರ್ಯಾಲಯ,  
ಚಾವಿನನಿ, ಮೈಸೂರು-570017  
Telephone No: 0821-247101



CHAMUNDESHWARI ELECTRICITY  
SUPPLY CORPORATION LIMITED  
(A Government of Karnataka Undertaking)  
Corporate Office,  
CESC, Mysuru-570017  
Web Site: www.cescmysore.karnataka.gov.in  
E-mail ID: gmtech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

### OFFICIAL MEMORANDUM

#### Preamble:

1. M/s Eaton Power Quality Pvt. Ltd., No-2, EVR Street, Sedarapet, Pondicherry-605111 is approved vendor in CESC vide OM No.CYS-1243/14.12.2020 valid up to November-2021 for supply of 3, 4 & 5 Way RMU.
2. The firm has applied for renewal of vendor approval on : 30.11.2021
3. The firm has paid Vendor approval registration and processing fees & Inspection Charges (To & Fro), of Rs 53,100/- vide Rt.No. 0025170/15.06.2022.
4. The subject matter was discussed in 75<sup>th</sup> T & VA Committee meeting held on 06.09.2022 and the committee resolved to accord renewal of vendor approval for 3, 4 & 5 Way RMU. Cables.
5. Proceedings of 75<sup>th</sup> T & VA committee meeting Memo No. CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/12478 Date: 13.09.2022.

#### Hence this official memorandum

CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/ *Cys-956* Date : 16 SEP 2022

I am hereby directed to communicate renewal of vendor approval to M/s Eaton Power Quality Pvt. Ltd., No-2, EVR Street, Sedarapet, Pondicherry-605111, as a vendor to the CESC consumers for the supply of the following materials for electrification of layouts, turnkey projects, M.S.Buildings, HT installations, etc., is for a period as mentioned below:

Sl. No.	Materials approved as per previous vendor approval	As per Common SR	Type test reports/ Drawings	Vendor approval Validity
	Compact RMUs, (VCB/SF6 Type) with Copper Busbar, 350MVA, 630 Amps as per IEC-62271/IS-3427			
i.	3 Way RMU, 2OD + 1VL (One Incomer + One Breakers + One Outgoing)	302340	Issued by CPRI on 23.11.2020	Valid up to November-2023
ii.	4 Way RMU, 2OD + 2VL (One Incomer + Two Breakers + One Outgoing)	302345	Issued by CPRI on 15.10.2018	
iii.	5 Way RMU, 2OD + 3VL (One Incomer + Three Breakers + One Outgoing)	302350	Issued by CPRI on 15.12.2018	

This vendor approval is subject to the following conditions:

- 1) The firm shall guarantee for all materials supplied by him for 12 Months (1 Year) From the date of commissioning.
- 2) The firm shall supply materials for the work as per the scheduled approval.
- 3) The above-mentioned materials shall conform to all the tests & specifications as per the relevant IS/IEC standards and the amendment made from time to time if any.
- 4) The above-mentioned material shall conform to the drawings and GTP approved by respective National Accreditation Board for Testing & Calibration Laboratories.
- 5) The Material shall be got inspected/tested in presence of the CESC inspecting officer prior to the supply.

P.T.O..

- 6) CESC reserves the right to withdraw the approval issued, in case of any violation of the approved drawings, GTP & specifications at any time.
- 7) Wherever applicable BIS License shall be got renewed before the expiry date.
- 8) For renewal of the vendor, the firm shall submit its requisition one month prior to the expiry of Validity Period with submitting relevant documents.

  
General Manager (Tech)  
CESC, Mysuru.

**Copy to:**

1. The Chief Engineer (Electy), CESC, Mysuru/Hassan.
2. The Chief General Manager (I/A), Corporate Office, CESC, Mysuru.
3. The General Manager, Purchase/Projects, Corporate Office, CESC, Mysuru.
4. All Superintending Engineers (Ele), O&M Circles, CESC.
5. All Executive Engineers (Ele), O&M Divisions, CESC.
6. The Deputy General Manager, TA & QC-1 & 2, CESC, Mysuru.
7. M/s Eaton Power Quality Pvt. Ltd., No-2, EVR Street, Sedarapet, Pondicherry-605111.
8. PS to MD/TA to DT, CESC to place the subject before MD/DT, CESC for information MF/OC.

*Received*  
*M/S*  
*20/9*

---

ನೋಂದಾಯಿತ ಕಛೇರಿ: ನಿಗಮ ಕಾರ್ಯಾಲಯ, ನಂ. 29, ವಿಜಯನಗರ, 2ನೇ ಹಂತ, ಹಿಂಕಲ್, ಮೈಸೂರು -570017.

Registered Office: Corporate Office, # 29, Vijayanagara, 2nd Stage, Hinkal, Mysuru-570017.



ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು  
ನಿಗಮ ನಿಯಮಿತ  
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)  
ನಿಗಮ ಕಾರ್ಯಾಲಯ,  
ಚಾವಿನನಿನಿ, ಮೈಸೂರು-570017  
Telephone No: 0821-2417101



CHAMUNDESHWARI ELECTRICITY  
SUPPLY CORPORATION LIMITED  
(A Government of Karnataka Undertaking)  
Corporate Office,  
CESC, Mysuru-570017  
Web Site: www.cescmysore.karnataka.gov.in  
E-mail ID: gmtech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

### OFFICIAL MEMORANDUM

#### Preamble:

1. M/s Arrivaa Power System Pvt. Ltd., No.96, 2nd Cross, Pipeline Road, Prem Nagar, Laggere, Bengaluru-560058 is approved vendor in CESC vide OM No.Cys-809/07.09.2021 for Metering Cubicle, LBS Panel, LT Feeders Pillars, HT VCB Panel & Compact Substation Panels valid up to April-2022.
2. The firm has applied for renewal of vendor approval on: 07.03.2022.
3. The firm has paid Vendor registration and processing fees of Rs 23,600/- vide Rt.No 0025056/12.04.2022.
4. The subject matter was discussed in 75<sup>th</sup> T & VA Committee meeting held on 06.09.2022 and the committee resolved to accord renewal of vendor approval for Metering Cubicle, LBS Panel, LT Feeders Pillars, HT VCB Panel & Compact Substation Panels.
5. Proceedings of 75<sup>th</sup> T & VA committee meeting Memo No. CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/12478 Date: 13.09.2022.

#### Hence this official memorandum

CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/ Cys - 955 Date : 6 SEP 2022

I am hereby directed to communicate vendor approval to M/s Arrivaa Power System Pvt. Ltd., No.96, 2nd Cross, Pipeline Road, Prem Nagar, Laggere, Bengaluru-560058, as a vendor to the CESC consumers for the supply of the following materials for electrification of layouts, turnkey projects, M.S.Buildings, HT installations, etc., is for a period as mentioned below:

Sl. No.	Materials approved as per Previous vendor approval	As per Common SR	Type test reports/ Validity	Vendor approval Validity
i.	11KV Metering Cubical without LBS	358351	Issued by CPRI on 31.01.2018& Valid up to 31.01.2028	Up to March-2024
ii.	11KV HT LBS Panel	506492	Issued by CPRI on 31.01.2018& Valid up to 31.01.2023	
iii.	11KV VCB & Panel	-	Issued by CPRI on 12.06.2020 & Valid up to 12.06.2025	
iv.	Compact Sub-Station	-	Issued by CPRI on 25.06.2021 Valid up to 25.06.2026	
v.	LT Feeder Panel	-	Issued by CPRI on 24.09.2018 Valid up to 24.09.2023	

This vendor approval is subject to the following conditions:

- 1) The firm shall guarantee for all materials supplied by him for 12 Months (1 Year) From the date of commissioning.
- 2) The firm shall supply materials for the work as per the scheduled approval.
- 3) The above-mentioned materials shall conform to all the tests & specifications as per the relevant IS/IEC standards and the amendment made from time to time if any.
- 4) The above-mentioned material shall conform to the drawings and GTP approved by respective National Accreditation Board for Testing & Calibration Laboratories.
- 5) The Material shall be got inspected/tested in presence of the CESC inspecting officer prior to the supply.

P.T.O..

- 6) CESC reserves the right to withdraw the approval issued, in case of any violation of the approved drawings, GTP & specifications at any time.
- 7) Wherever applicable BIS License shall be got renewed before the expiry date.
- 8) For renewal of the vendor, the firm shall submit its requisition one month prior to the expiry of Validity Period with submitting relevant documents.

  
General Manager (Tech)  
CESC, Mysuru.

**Copy to:**

1. The Chief Engineer (Electy), CESC, Mysuru/Hassan.
2. The Chief General Manager (I/A), Corporate Office, CESC, Mysuru.
3. The General Manager, Purchase/Projects, Corporate Office, CESC, Mysuru.
4. All Superintending Engineers (Ele), O&M Circles, CESC.
5. All Executive Engineers (Ele), O&M Divisions, CESC.
6. The Deputy General Manager, TA & QC-1 & 2, CESC, Mysuru.
7. M/s Arrivaa Power System Pvt. Ltd., No.96, 2nd Cross, Pipeline Road, Prem Nagar, Laggere, Bengaluru-560058.
8. PS to MD/TA to DT, CESC to place the subject before MD/DT, CESC for information MF/OC.

*Received*  
*7/5/19*

---

ನೋಂದಾಯಿತ ಕಛೇರಿ: ನಿಗಮ ಕಾರ್ಯಾಲಯ, ನಂ. 29, ವಿಜಯನಗರ, 2ನೇ ಹಂತ, ಹಿಂಕಲ್, ಮೈಸೂರು -570017.

Registered Office: Corporate Office, # 29, Vijayanagara, 2nd Stage, Hinkal, Mysuru-570017.



ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು  
ನಿಗಮ ನಿಯಮಿತ  
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)  
ನಿಗಮ ಕಾರ್ಯಾಲಯ,  
ಚಾವಿನನಿನಿ, ಮೈಸೂರು-570017  
Telephone No: 0821-2417101



CHAMUNDESHWARI ELECTRICITY  
SUPPLY CORPORATION LIMITED  
(A Government of Karnataka Undertaking)  
Corporate Office,  
CESC, Mysuru-570017  
Web Site: www.cescmysore.karnataka.gov.in  
E-mail ID: gmtech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

### OFFICIAL MEMORANDUM

#### Preamble:

1. M/s Paras Power Engineering Pvt., Ltd., and Plot No: 434, 12th Cross, IV Phase, Peenya Industrial Area, Bengaluru-560058 is approved vendor in CESC for HT Metering Cubicles CT's & PT's.
2. The firm has applied for Inclusion of additional material in vendor approval on: 06.09.2022.
3. The firm has paid Vendor approval registration and processing of Rs 23,600/- vide Rt.No. 0025302/16.09.2022.
4. The subject matter was discussed in 76th T & VA Committee meeting held on 29.10.2022 and the committee resolved to accord Inclusion of vendor approval for LT Cubicle Metering Instrumental Transformers in CESC area for a period of two years i.e., up to November-2023.
5. Proceedings of 76th T & VA committee meeting Memo No. CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/16439 Date: 17.11.2022.

#### Hence this official memorandum

CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/ *15/11/22* Date : 18 NOV 2022

I am hereby directed to communicate approval for M/s Paras Power Engineering Pvt., Ltd., and Plot No: 434, 12th Cross, IV Phase, Peenya Industrial Area, Bengaluru-560058 as a vendor to the CESC consumers for the supply of the following additional material for electrification of layouts, turnkey projects, M.S.Buildings, HT installations, etc., is for a period as mentioned below:

Sl. No.	Materials approved as per Previous vendor approval	As per Common SR	Type test reports/ Validity	Vendor approval Validity
i.	LT Current Transformers, indoor, resin cast of ratio 250/1A, 2.5VA, 0.2S	-	Issued by CPRI for 250/1A on 11.05.2022	Up to November-2023
ii.	440V/ $\sqrt{3}$ :110V/ $\sqrt{3}$ , 1 $\Phi$ Voltage Transformer, indoor, resin cast, 50Hz, 5VA, 0.2Accuracy	-	Issued by CPRI on 11.05.2022	
iii.	3Phase 4 wire LT Metering Cubicle	-	Issued by CPRI on 23.06.2022	

This vendor approval is subject to the following conditions:

- 1) The firm shall guarantee for all materials supplied by him for 12 Months (1 Year) from the date of commissioning.
- 2) The firm shall supply materials for the work as per the scheduled approval.
- 3) The above-mentioned materials shall conform to all the tests & specifications as per the relevant IS/IEC standards and the amendment made from time to time if any.
- 4) The above-mentioned material shall conform to the drawings and GTP approved by respective National Accreditation Board for Testing & Calibration Laboratories.
- 5) The Material shall be got inspected/tested in presence of the CESC inspecting officer prior to the supply.
- 6) CESC reserves the right to revoke the approval granted at any time if the approved designs, GTP, or specifications are violated.
- 7) Where applicable, the type test certificate/BIS license should be renewed prior to the expiry date.
- 8) For renewal of the vendor, the firm shall submit its requisition one month prior to the expiry of Validity Period with submitting relevant documents.

*[Signature]*  
General Manager (Tech)  
CESC, Mysuru.

*Received on 23/11/22*

*[Signature]*  
9916924505

**Copy to:**

1. The Chief Engineer (Electy), CESC, Mysuru/Hassan.
2. The Chief General Manager (I/A), Corporate Office, CESC, Mysuru.
3. The General Manager, Purchase/Projects, Corporate Office, CESC, Mysuru.
4. All Superintending Engineers (Ele), O&M Circles, CESC.
5. All Executive Engineers (Ele), O&M Divisions, CESC.
6. The Deputy General Manager, TA & QC-1 & 2, CESC, Mysuru.
7. M/s Paras Power Engineering Pvt., Ltd., and Plot No: 434, 12th Cross, IV Phase, Peenya Industrial Area, Bengaluru-560058.
8. PS to MD/TA to DT, CESC to place the subject before MD/DT, CESC for information MF/OC.

---

ನೋಂದಾಯಿತ ಕಛೇರಿ: ನಿಗಮ ಕಾರ್ಯಾಲಯ, ನಂ. 29, ವಿಜಯನಗರ, 2ನೇ ಹಂತ, ಹಿಂಕಲ್, ಮೈಸೂರು -570017.

Registered Office: Corporate Office, # 29, Vijayanagara, 2nd Stage, Hinkal, Mysuru-570017.



ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು  
ನಿಗಮ ನಿಯಮಿತ  
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)  
ನಿಗಮ ಕಾರ್ಯಾಲಯ,  
ಬಾವಿಸನಿನಿ, ಮೈಸೂರು-570017  
Telephone No: 0821-2417101



CHAMUNDESHWARI ELECTRICITY  
SUPPLY CORPORATION LIMITED  
(A Government of Karnataka Undertaking)  
Corporate Office,  
CESC, Mysuru-570017  
Web Site: www.cescmysore.karnataka.gov.in  
E-mail ID: gmtech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

### OFFICIAL MEMORANDUM

#### Preamble:

1. M/s Kalpa Elektrikal Pvt. Ltd., P.B.No 4413, 149/25, III Main Industrial Town, Rajajinagara, Bengaluru is approved vendor in CESC for LT CTs, 11KV Indoor/Outdoor CTs and PTs, & 11KV Outdoor CTs and PTs
2. The firm has applied for Inclusion of additional material in vendor approval on : 05.03.2022
3. The firm has paid Vendor approval registration and processing of Rs 23,600/- vide Rt.No. 0025297/14.09.2022.
4. The subject matter was discussed in 76<sup>th</sup> T & VA Committee meeting held on 29.10.2022 and the committee resolved to accord Inclusion of vendor approval for LT Cubicle Metering Instrumental Transformers in CESC area up to November-2023.
5. Proceedings of 76<sup>th</sup> T & VA committee meeting Memo No. CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/16439 Date: 17.11.2022.

#### Hence this official memorandum

CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/1249 Date : 18 NOV 2022

I am hereby directed to communicate approval for M/s Kalpa Elektrikal Pvt. Ltd., P.B.No 4413, 149/25, III Main Industrial Town, Rajajinagara, Bengaluru as a vendor to the CESC consumers for the supply of the following additional material for electrification of layouts, turnkey projects, M.S.Buildings, HT installations, etc., is for a period as mentioned below:

Sl. No.	Materials approved as per Previous vendor approval	As per Common SR	Type test reports/ Validity	Vendor approval Validity
i.	LT Current Transformers, indoor, resin cast of ratio 250/1A, 2.5VA, 0.2S	-	Issued by CPRI for 250/1A on 24.05.2022	Up to November-2023
ii.	440V/√3:110V/√3, 1Φ Voltage Transformer, indoor, resin cast, 50Hz, 5VA, 0.2Accuracy	-	Issued by CPRI on 17.06.2022	

This vendor approval is subject to the following conditions:

- 1) The firm shall guarantee for all materials supplied by him for 12 Months (1 Year) from the date of commissioning.
- 2) The firm shall supply materials for the work as per the scheduled approval.
- 3) The above-mentioned materials shall conform to all the tests & specifications as per the relevant IS/IEC standards and the amendment made from time to time if any.
- 4) The above-mentioned material shall conform to the drawings and GTP approved by respective National Accreditation Board for Testing & Calibration Laboratories.
- 5) The Material shall be got inspected/tested in presence of the CESC inspecting officer prior to the supply.
- 6) CESC reserves the right to revoke the approval granted at any time if the approved designs, GTP, or specifications are violated.
- 7) Where applicable, the type test certificate/BIS license should be renewed prior to the expiry date.
- 8) For renewal of the vendor, the firm shall submit its requisition one month prior to the expiry of Validity Period with submitting relevant documents.

General Manager (Tech)  
CESC, Mysuru.

**Copy to:**

1. The Chief Engineer (Electy), CESC, Mysuru/Hassan.
2. The Chief General Manager (I/A), Corporate Office, CESC, Mysuru.
3. The General Manager, Purchase/Projects, Corporate Office, CESC, Mysuru.
4. All Superintending Engineers (Ele), O&M Circles, CESC.
5. All Executive Engineers (Ele), O&M Divisions, CESC.
6. The Deputy General Manager, TA & QC-1 & 2, CESC, Mysuru.
7. M/s Kalpa Elektrikal Pvt. Ltd., P.B.No 4413, 149/25, III Main Industrial Town, Rajajinagara, Bengaluru.
8. PS to MD/TA to DT, CESC to place the subject before MD/DT, CESC for information MF/OC.

---

ನೋಂದಾಯಿತ ಕಛೇರಿ: ನಿಗಮ ಕಾರ್ಯಾಲಯ, ನಂ. 29, ವಿಜಯನಗರ, 2ನೇ ಹಂತ, ಹಿಂಕಲ್, ಮೈಸೂರು -570017.

Registered Office: Corporate Office, # 29, Vijayanagara, 2nd Stage, Hinkal, Mysuru-570017.



ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು  
ನಿಗಮ ನಿಯಮಿತ  
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)  
ನಿಗಮ ಕಾರ್ಯಾಲಯ,  
ಚಾವಿನಿನಿ, ಮೈಸೂರು-570017  
Telephone No: 0821-241701



CHAMUNDESHWARI ELECTRICITY  
SUPPLY CORPORATION LIMITED  
(A Government of Karnataka Undertaking)  
Corporate Office,  
CESC, Mysuru-570017  
Web Site: www.cescmysore.karnataka.gov.in  
E-mail ID: gmtech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

## OFFICIAL MEMORANDUM

### Preamble:

1. M/s Sankhala Vinyl Pvt Ltd., 126, 7th Main, 3rd Stage, Industrial Estate, Peenya Industrial Area, Bengaluru-560058 is approved vendor in CESC vide OM No. cys-893/13.10.2020 valid upto July-2022 for Heat Shrinkable Cable Termination & Jointing Kit.
2. The firm has applied for renewal of vendor approval on: 11.08.2022.
3. The firm has paid Vendor registration and processing fees of Rs 23,600/- vide Rt.No 0025254/17.8.2022.
4. The subject matter was discussed in 76<sup>th</sup> T & VA Committee meeting held on 29.10.2022 and the committee resolved to accord renewal of vendor approval for Heat Shrinkable Cable Termination & Jointing Kit in CESC area up to July-2024.
5. Proceedings of 76<sup>th</sup> T & VA committee meeting Memo No. CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/16439 Dated:17.11.2022.

### Hence this official memorandum

CESC/GM(T)/DGM(T)/AGM(T-1)/C1-2284/2022-23/ *cys-1248* Date : *18 NOV 2022*

I am hereby directed to communicate approval for renewal of M/s Sankhala Vinyl Pvt Ltd., 126, 7th Main, 3rd Stage, Industrial Estate, Peenya Industrial Area, Bengaluru-560058, as a vendor to the CESC consumers for the supply of the following materials for electrification of layouts, turnkey projects, M.S.Buildings, HT installations, etc., is for a period as mentioned below:

Sl. No	Materials approved as per previous vendor approval	As per Common SR	Type test reports/ Drawings	Vendor approval Validity
i.	11KV Heat Shrinkable Type Transition Jointing Kit for XLPE Cable up to 240 sq.mm	-	Issued by CPRI on 23.11.2020	Up to July-2024
ii.	11KV Heat Shrinkable Indoor/Outdoor Type Cable Termination Kit for XLPE cable up to 240 sq.mm	-	Issued by CPRI on 15.10.2018	

This vendor approval is subject to the following conditions:

- 1) The firm shall guarantee for all materials supplied by him for 12 Months (1 Year) From the date of commissioning.
- 2) The firm shall supply materials for the work as per the scheduled approval.
- 3) The above-mentioned materials shall conform to all the tests & specifications as per the relevant IS/IEC standards and the amendment made from time to time if any.
- 4) The above-mentioned material shall conform to the drawings and GTP approved by respective National Accreditation Board for Testing & Calibration Laboratories.
- 5) The Material shall be got inspected/tested in presence of the CESC inspecting officer prior to the supply.
- 6) CESC reserves the right to revoke the approval granted at any time if the approved designs, GTP, or specifications are violated.
- 7) Where applicable, the type test certificate/BIS license should be renewed prior to the expiry date.
- 8) For renewal of the vendor, the firm shall submit its requisition one month prior to the expiry of Validity Period with submitting relevant documents.

General Manager (Tech)  
CESC, Mysuru.

**Copy to:**

1. The Chief Engineer (Electy), CESC, Mysuru/Hassan.
2. The Chief General Manager (I/A), Corporate Office, CESC, Mysuru.
3. The General Manager, Purchase/Projects, Corporate Office, CESC, Mysuru.
4. All Superintending Engineers (Ele), O&M Circles, CESC.
5. All Executive Engineers (Ele), O&M Divisions, CESC.
6. The Deputy General Manager, TA & QC-1 & 2, CESC, Mysuru.
7. M/s Sankhala Vinyl Pvt Ltd., 126, 7th Main, 3rd Stage, Industrial Estate, Peenya Industrial Area, Bengaluru-560058.
8. PS to MD/TA to DT, CESC to place the subject before MD/DT, CESC for information MF/OC.

8 NOV 2023

---

ನೋಂದಾಯಿತ ಕಛೇರಿ: ನಿಗಮ ಕಾರ್ಯಾಲಯ, ನಂ. 29, ವಿಜಯನಗರ, 2ನೇ ಹಂತ, ಹಿಂಕಲ್, ಮೈಸೂರು -570017.

Registered Office: Corporate Office, # 29, Vijayanagara, 2nd Stage, Hinkal, Mysuru-570017.