

CHAMUNDESHWARI ELECTRICITY SUPPLY CORPORATION LIMITED, MYSORE

(A Government of Karnataka Undertaking)

FAX No 0821-2417107
E-Mail: seccesc@gmail.com
Web : www.cescmysore.org
CIN: U40109KA2004SGC03517



Corporate Office
29, Vijayanagar 2nd Stage,
Hinkal, Mysuru -570 017

No: GM(Coml)/DGM(RA-2)/APRO/F-16/2018-19/ *CYS-1331* Date: **28 DEC 2018**
Encl:

All EE's /AEE's of
O & M Divisions/Sub-Divisions/MT Division,
CESC, Mysore

Sir,


Sub: Inspection of Electrical Inspector for Solar Rooftop generation units installed as per the KEREC (Implementation of Solar Rooftop Photovoltaic power plant) Regulations, 2016-Reg

Ref: GoK Notification No.:135 EBS 2018 dt: 27.08.2018

With reference to the subject, the Government of Karnataka vide no.135 EBS 2018 dt: 27.08.2018 has issued notification in regard of Inspection of the Solar Rooftop generation units installed as per the KEREC (implementation of Solar Rooftop Photovoltaic Power Plants) Regulations, 2016.

In this regard, I am directed to inform all the field Officers of O&M Divisional/Sub-Divisional Officers to take necessary action as per the GoK notification cited under reference. The copy of the notification is herewith enclosed for needful action.

Yours faithfully,


28/12/2018
General Manager (Coml)
Corporate Office, CESC Mysore

GOVERNMENT OF KARNATAKA

NO. EN 135 EBS 2018

Karnataka Government Secretariat,
Vikasa Soudha,
Bengaluru. Dated: 27.08.2018.

NOTIFICATION

In exercise of the powers conferred by Regulation 32 of the Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2010 and in continuation to the Notification No. EN 99 EBS 2016(III) Dt. 03-09-2016 issued in this behalf, the Govt. of Karnataka hereby notifies that the generating units having capacity to produce electricity above 1 MW from Solar Rooftop sources of energy shall be inspected by the Electrical Inspector or any officer appointed to assist the Electrical Inspector before commissioning. Solar rooftop generation units installed as per the KERC (Implementation of Solar Rooftop Photovoltaic Power Plant) Regulations, 2016 shall be inspected periodically as per Regulations 30 of Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2010.

Provided that the installations belonging to Govt. of India or its undertaking are excluded from inspection by the Electrical Inspector of the State.

BY ORDER AND IN THE NAME OF
THE GOVERNOR OF KARNATAKA

(Signature)
(T.MANJAPPA)

Government Under Secretary (I/c),
Energy Department.

To:-

The Compiler, Karnataka Gazette, Government Press, Bangalore, with a request to publish in the forthcoming Gazette, and to furnish 50 printed copies for reference, to the Government.

Copy to:-

1. The Accountant General (A& E), Karnataka, Bangalore.
2. The Chief Secretary to Government of Karnataka, Vidhana Soudha, Bangalore.
3. The Secretary, Ministry of Power, Government of India, New Delhi.