

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು
ನಿಗಮ ನಿಯಮಿತ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ನಿಗಮ ಕಾರ್ಯಾಲಯ,
ಜಾವಿನನಿನಿ, ಮೈಸೂರು-570017
Telephone No:0821-2417107



CHAMUNDESHWARI ELECTRICITY
SUPPLY CORPORATION LIMITED
(A Government of Karnataka Undertaking)
Corporate Office,
CESC, Mysuru-570017
Web Site: www.cescmysore.org
E-mail ID: gmttech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

No: CESC/GMT/DGM (MIS)/AEE-1/M/ 2023-24/
Encl: Sheet

Cys-644 Date:

09 AUG 2023

OFFICIAL MEMORANDUM

Sub: Assignment of 11 kV Feeder codes - reg.

- Ref:** 1. T.O. Ltr. No: CESC/GM (T)/MIS/14-15/Cys-186 Dtd 17.6.2014.
2. EEE(O)/AEE(O)/AE(T)/2023-24/2104-05 Dtd: 28.07.2023.
3. EEE(O)/AEE(O)/Mandya Div/2023-24/1475-78 Dtd: 19.07.2023.
4. EEE(O)/AEE(O)/Mandya Div/1603-06/1603-06 Dtd: 02.08.2023.
5. EEE(O)/AEE(O)/AE(T)/23-24/1512-13 Dtd: 17.07.2023.
6. EEE(O)/AEE(O)/AE(T)/23-24/1955-56 Dtd: 12.07.2023.
7. EEE(O)/AEE(O)/AE(T)-2/VVM Div/23-24/2579-82 Dtd:18.07.2023.
8. Director (Technical) approval note Dated: 07.08.2023

Anent to the above subject, as per the reports and recommendations by the O&M Divisional Officers under reference (2) and (6) wherein, it is stated that 11kV feeders have been commissioned and requested to issue feeder codes. Accordingly, I am directed to convey the approval for allocating the 11kV feeder codes as desired by the field officers in the interest of corporate services.

The details are outlined below:

No	Division Name	Subdivision Name	Sub-Station Name	11 kV Feeder Name	Type of Feeder	Feeder code
1	Nanjanagudu	Nanjanagudu-1	Thayuru	Salundi	IP	12A8
2	Nanjanagudu	Nanjanagudu-1	Thayuru	Haropura	NJY	12A9
3	Mandya	Keragodu	Kolkarnadoddi	B Yarahalli	IP	3179
4	Mandya	Keragodu	Kolkarnadoddi	Kammanayakanahalli	IP	317A
5	Mandya	Kottathi	Hampapura	Gantegowdanahalli	IP	312B
6	Mandya	Kottathi	Hampapura	Shamboonahalli	IP	312C
7	Mandya	Kottathi	220kV Tubinakere	University	IN	3169
8	Pandavapura	Pandavapura	Pandavapura	Kyathanahalli	NJY	342F
9	Chennarayapatna	C.R Patna	220kV Yachenahalli	Bindenahalli	IP	45A7
10	Chennarayapatna	C.R Patna	220kV Yachenahalli	Chikkaganni	IP	45A8
11	Chennarayapatna	C.R Patna	220kV Yachenahalli	SRD Nagara	NJY	45A9

As per the request letter received by the O&M Sub-Divisional Officer under references (7) wherein, it is stated that the load of the 11kV feeder mentioned below were shifted to other feeders due to frequent cable faults and requested to remove the feeders at our end. Accordingly, the changes are made as below:

Contd....2

No	Division Name	Sub-Station Name	Feeder Code	Feeder details As Existing		Remarks
				Name	Category	
1	V.V Mohalla	Belagola	352D	Koorgalli	Industrial	Removed from the existing list as per divisional officer request
2	V.V Mohalla	Yelawala (Karakanaahalli)	11F6	Aloka WW	Water Supply	
3	V.V Mohalla	220kV Hootagalli	1178	Vinyas	Industrial	

The same shall be updated in the TRM/ DTLMS and Urja-Mitra software data base of respective O&M division/subdivision/section and same may be intimated to all the concerned field officers of CESC and KPTCL nodal centres and respective sub-stations. Further, Scheduled and Un-Scheduled interruptions of any feeder should be hosted in the Urja- Mitra Portal for prior intimation to the consumer.


General Manager (Tech)
CESC, Mysuru.

Copy to:

1. The Chief Engineer (Ele) O&M Zone, CESC, Mysore/Hassan.
2. The Superintending Engineer (El), O&M Circle, Mysore/Mandya/ Hassan, CESC.
3. The General Manager (Projects), Corporate Office, CESC, Mysore.
4. The Executive Engineer (Ele), O&M Division, V.V Mohalla/ Nanjanagudu/Mandya/Pandavapura/Chennarayapatna, CESC.
5. The Executive Engineer (Ele), TL&SS Division, Hootagalli/ Hebbani/ Mandya Chamarajanagar/ Hassan/ H.N Pura, KPTCL – for reference.
6. The Deputy General Manager (Track lead), corporate office, CESC, Mysore.
7. The Deputy General Manager (DSM), corporate office, CESC, Mysore.
8. The Assistant Executive Engineer (Ele), Hootagalli/Nanjanagudu-1/ Keragodu/ Kothathi/ Pandavapura/Chennarayapatna, CESC.
9. The Assistant Executive Engineer (Ele), DCC, Corporate Office, CESC, Mysore.
10. M/s Idea Infinity IT Solutions Pvt. Ltd, #218, 5th floor, JP Royale, Sampige road, Malleshwaram, Bangalore-560003 to update in DTLMS Software.
11. PS to Hon'ble Managing Director /TA to Diector (Technical) to place before Hon'ble Managing Director/ Diector (Technical)
OC/MF