



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಸಂಖ್ಯೆ: ಇಎನ್ 70 ವಿಎಸ್‌ಸಿ 2015

ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಚಿವಾಲಯ
ವಿಕಾಸ ಸೌಧ,
ಬೆಂಗಳೂರು, ದಿನಾಂಕ: 13-05-2016

ಇಂದ,

ಸರ್ಕಾರದ ಅಪರ ಮುಖ್ಯ ಕಾರ್ಯದರ್ಶಿಗಳು,
ಇಂಧನ ಇಲಾಖೆ, ವಿಕಾಸಸೌಧ,
ಬೆಂಗಳೂರು.

“ತುರ್ತು”

ಇವರಿಗೆ,

ವ್ಯವಸ್ಥಾಪಕ ನಿರ್ದೇಶಕರು,
ಬೆಸ್ಕಾಂ/ಹೆಸ್ಕಾಂ/ಮೆಸ್ಕಾಂ/ಚೆಸ್ಕಾಂ/ಸೆಸ್ಕಾಂ/ಹುಕ್ಕೇರಿ.

ಮಾನ್ಯರೇ,

ವಿಷಯ: ಗ್ರಿಡ್ ಸಂಪರ್ಕಿತ ಮೇಲ್ಭಾಗದ ಸೌರ ವಿದ್ಯುತ್ ಘಟಕಗಳ ಸ್ಥಾಪನೆ ಕುರಿತು.

ಉಲ್ಲೇಖ: ಕರ್ನಾಟಕ ವಿದ್ಯುಚ್ಛಕ್ತಿ ನಿಯಂತ್ರಣ ಆಯೋಗ ರವರ ಅರೆ ಸರ್ಕಾರಿ ಪತ್ರ

ಸಂಖ್ಯೆ: KERC/D.O No.330 ದಿನಾಂಕ: 06.05.2016.

ಮೇಲ್ಕಂಡ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಅಧ್ಯಕ್ಷರು, ಕರ್ನಾಟಕ ವಿದ್ಯುಚ್ಛಕ್ತಿ ನಿಯಂತ್ರಣ ಆಯೋಗ ರವರ ಉಲ್ಲೇಖಿತ ಪತ್ರದನ್ವಯ, ಈಗಾಗಲೇ ಗ್ರಿಡ್ ಸಂಪರ್ಕಿತ ಮೇಲ್ಭಾಗದ ಸೌರ ವಿದ್ಯುತ್ ಘಟಕಗಳ ಸ್ಥಾಪನೆಗೆ ವಿದ್ಯುತ್ ವಿತರಣಾ ಕಂಪನಿಗಳು ಹಳೆಯ ಜಕಾತಿ ದರದಂತೆ, ಅಂದರೆ ಮಾನ್ಯ ಆಯೋಗದ ಆದೇಶ ದಿನಾಂಕ:02.05.2016ಕ್ಕೆ ಹಿಂದೆ ಮಾಡಿಕೊಂಡಿರುವ ವಿದ್ಯುತ್ ಖರೀದಿ ಒಪ್ಪಂದಗಳಿಗೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಎಲ್ಲಾ SRTPV ಪಾಲುದಾರರ ಹಿತ ದೃಷ್ಟಿಯನ್ನು ಗಮನದಲ್ಲಿಟ್ಟುಕೊಂಡು ಸರ್ಕಾರಕ್ಕೆ ಕೆಲವು ಸಲಹೆಗಳನ್ನು ನೀಡಲಾಗಿರುತ್ತದೆ(ಪ್ರತಿ ಲಗತ್ತಿಸಿದೆ).

ಅದರಂತೆ, ಈ ಸಂಬಂಧ ಮಾನ್ಯ ಆಯೋಗದಿಂದ ಸ್ವೀಕೃತವಾಗಿರುವ ಉಲ್ಲೇಖಿತ ಪತ್ರದಲ್ಲಿನ ಸಲಹೆಗಳನ್ನು ಕಡ್ಡಾಯವಾಗಿ ತಮ್ಮ ಕಂಪನಿ ವ್ಯಾಪ್ತಿಯಲ್ಲಿ ತಕ್ಷಣದಿಂದಲೇ ಜಾರಿಗೊಳಿಸುವಂತೆ ಮತ್ತು ಏಳು ದಿನಗಳೊಳಗಾಗಿ ಅನುಷ್ಠಾನ ವರದಿಯನ್ನು ಸರ್ಕಾರಕ್ಕೆ ಸಲ್ಲಿಸುವಂತೆ ಕೋರಲು ನಿರ್ದೇಶಿತನಾಗಿದ್ದೇನೆ.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

(ವಿಶ್ವನಾಥ ಪಿ. ಹಿರೇಮಠ)

ಸರ್ಕಾರದ ಉಪ ಕಾರ್ಯದರ್ಶಿ

ಇಂಧನ ಇಲಾಖೆ ಫೋನ್: 22034679

ಪ್ರತಿ:

1. ಕಾರ್ಯದರ್ಶಿ, ಕರ್ನಾಟಕ ವಿದ್ಯುತ್ ನಿಯಂತ್ರಣ ಆಯೋಗ, ನಂ. 9/2, 6ನೇ ಮತ್ತು 7ನೇ ಮಹಡಿ, ಮಹಾಲಕ್ಷ್ಮಿ ಭೇಂಬರ್ಸ್, ಎಂ.ಜಿ. ರಸ್ತೆ, ಬೆಂಗಳೂರು.
2. ವ್ಯವಸ್ಥಾಪಕ ನಿರ್ದೇಶಕರು, ಕರ್ನಾಟಕ ನವೀಕರಿಸಬಹುದಾದ ಇಂಧನ ಅಭಿವೃದ್ಧಿ ನಿಯಮಿತ, ನಂ. 39, “ಶಾಂತಿ ಗೃಹ” ಪ್ಯಾಲೆಸ್ ರಸ್ತೆ, ಭಾರತ್ ಸ್ಕೌಟ್ಸ್ ಅಂಡ್ ಗೈಡ್ಸ್ ಬಿಲ್ಡಿಂಗ್, ಬೆಂಗಳೂರು-560001.

M.K. Shankaralinge Gowda, IAS (Retd.)

Chairman



Karnataka Electricity Regulatory Commission

No. 9/2, 6th & 7th Floor, Mahalaxmi Chambers,
Mahatma Gandhi Road, Bengaluru - 560 001.

Tel : +91-080-25320356, Fax: +91-080-25320338

Email : kerc-ka@nic.in Website : www.karnataka.gov.in/kerc

No: KERC/D.O No. 330

Date: 6th May, 2016

Dear Sri

Ravi Kumar,

The Government's attention is drawn to Commission's Order dated 2nd May, 2016 in the matter of determination of revised tariff for solar Rooftop and small photovoltaic power plants up to one MW. With the issue of this order the earlier tariff of Rs.9.56 per unit determined as per Order dated 10th October, 2013 will not be applicable to the PPAs to be signed on or after 2nd May, 2016.

The Commission has been approving PPAs in respect solar projects of above 500 kW and up to one MW, with lower capacity PPAs being executed at the ESCOM level. As observed in the Commission's Tariff Order dated 2nd May, 2016, the proposed capacity addition as per the PPAs executed has been far beyond the capacity envisaged by the State and Central Government.

In order to limit the capacity addition to the desired levels in the interest of all the stakeholders, the Commission considers it necessary to issue the following advisory to the Government:

1. No extension of time shall be granted for commissioning of the plants in respect of PPAs which have already been executed at the previous tariff.
2. In order to monitor and regulate the commissioning of the plants of all capacities for which PPAs have already been executed, all the ESCOMs shall host on their websites, the details of such plants, in the following format by 20th May, 2016:

AC : GY/11/11/1835
Date: 12/5/2016

XXX
Gowda
12/5/2016
EE (recd)

12/5

: 2 :

Sl.No.	Name of the first party	Capacity in KWs	Type of Structure/ Building	Location /division of the ESCOM	Date of signing PPA	Date of Approval by KERC/ESCOM	Scheduled date of Commissioning	Actual Date of Commissioning
1								
2								
xxxx								
	Total Capacity in MWs							


3. The ESCOMs shall not allow any change of location of the project or revision of the capacity of the project.
4. The norms for grid connectivity shall be adhered to strictly as per the orders of the Commission wherein, evacuation of SRTPV beyond 50kW is allowed at 11kV duly ensuring that the cost of any augmentation/strengthening of the lines/switchgear up to the point of inter-connection is borne by the SRTPV owner.

The Government is requested to ensure implementation of the above advisory at the earliest.

With regards,

Yours Sincerely

20.1.



6/5/16

Sri P.Ravi Kumar, IAS
Addl. Chief Secretary to Govt.
Department of Energy,
Government of Karnataka,
Vikasa Soudha,
BENGALURU – 560 001.