

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ
ನಿಯಮಿತ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ನಿಗಮ ಕಾರ್ಯಾಲಯ,
ಜಾವಿಸನಿನಿ, ಮೈಸೂರು-570017
Telephone No:0821-2417107



CHAMUNDESHWARI ELECTRICITY
SUPPLY CORPORATION LIMITED
(A Government of Karnataka Undertaking)
Corporate Office,
CESC, Mysuru-570017
Web Site: www.cescmysore.org.
E-mail ID: gmttech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

CESC/GM(T)/DGM/AGM-2(MIS)/22-23/ 13648-55 Date: 02 NOV 2023

The Chief Engineer (Ele)
O&M Zone, CESC,
Mysuru.

Sir,

Sub: Approval for availing line Clear of 220 KV Adakanahally-Begur DC Line and 66 KV Paniyanhundi-Hemmargala Line for Providing LILO arrangement to 66/11kV Karya Sub-Station by stringing 66kV Second circuit for a distance of about 7.301Kms along with one number of 66kV Terminal bay at 66/11kV Karya sub-station in Nanjangud Taluk, Mysuru District.

Ref: 1. CEE O & M Zone, Mysuru letter from email dtd.02.11.2023.

Anent to the above subject vide ref (1) it is stated that Chief Engineer(Ele), Transmission Zone, KPTCL, Mysore has requested to accord approval to for Line Clear of 220KV Adakanahally - Begur DC Line and 66 KV Paniyanhundi-Hemmargala Line for the work of providing LILO arrangement to 66/11kV Karya Sub-Station by stringing 66kv Second circuit for a distance of about 7.301Kms along with one number of 66kV Terminal bay at 66/11kV Karya sub-station in Nanjangudu Taluk, Mysuru District. . In continuation in the above letter it is mentioned the details work carried out and alternate arrangement for sub-stations during LC period.

Further, it is stated that Superintending Engineer (Elec.), O&M Circle, CESC, Mysore has accorded concurrence for availing line clear on 05.11.2023 for the above said work and you are also recommended for the line clear.

In view of the above, I am hereby directed to accord approval to avail line clear on 220kv Adakanahally -Begur DC Line, Paniyanhundi-Hemmargala Line and IPP M/s Nanj Solar and 66/11 kV Karya S/s from 10:00Hrs to 18:00Hrs of 05.11.2023 for stringing two span of 66kv Transmission Line, to change the suspension type to Anchor type at Tower No 92 to maintain safety clearance between 220kv line and 66kv Line. Further, **instruct the concerned Executive Engineer (Ele) O & M Division & to issue paper notification regarding line clear and interruption of IP feeders power supply & also instruct to carry out feeder maintenance during LC period.**

Yours faithfully

General Manager (Tech)
CESC, Mysuru.

Copy to:

1. The Chief Engineer (Ele), Transmission Zone Mysuru, KPTCL for information and to instruct the concerned TL & SS to carry out station maintenance during LC period.
2. The Superintending Engineer (Ele), O&M Circle, CESC Mysuru/Chamrajnagar-Kodagu/Mandya.
3. Executive Engineer(Ele.), O & M Division Nanjangud/Chamrajnagar/Kollegala.
4. The Assistant Executive Engineer (Ele), DCC, CESC, Mysuru.
5. PS to MD/TA to DT To place before MD and DT.

MF/OC