

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು  
ನಿಗಮ ನಿಯಮಿತ  
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)  
ನಿಗಮ ಕಾರ್ಯಾಲಯ,  
ಚಾವಿಸನಿನಿ, ಮೈಸೂರು-570017  
Telephone No:0821-2417107



**CHAMUNDESHWARI ELECTRICITY  
SUPPLY CORPORATION LIMITED**  
(A Government of Karnataka Undertaking)  
Corporate Office,  
CESC, Mysuru-570017  
Web Site: [www.cescmysore.org](http://www.cescmysore.org).  
E-mail ID: [gmtech@cescmysore.org](mailto:gmtech@cescmysore.org)

Company Identity Number[CIN]:- U40109KA2004SGC035177

No: CESC/GMT/DGM(MIS)/AGM-2/21-22/13409-12

Date: 15/11/2021

Chief Engineer (Ele.,)  
CESC, O&M Zone  
Mysuru.

Sir,

**Sub:** Approval for availing Line clear of 66KV Devnur (Nanjangudu) & Suttur Substations along with I/c Line on 15.11.2021 between 07:00Hrs to 16:00Hrs - on Emergency basis-Reg.

**Ref:** 1.Letter No.CESC/CEE/SEE(O)/AE/2021-22/4066-68 dated:10.11.2021 of Chief Engineer(Ele), O&M Zone, CESC Mysore.  
2. Director(Technical) approval note dtd.15.11.2021.

\*\*\*\*\*

Anent to the above subject, vide your letter under reference(1), it is stated that Chief Engineer(Ele), Transmission Zone, KPTCL, Mysore has requested to arrange concurrence for availing Line clear of 66KV Devnur (Nanjangudu) & Suttur Substations along with associated lines for the below mentioned works on 15.11.2021, 24.11.2021 and on 30.11.2021 between 07:00Hrs to 18:00Hrs .

**1. 66kv Devanur (Nanjangudu) to Hemmaragala S/c Line in Mysore District:**

Since, 66kv Kadakola-Devanur (Nanjangudu) S/c Line from EHT M/s Kayathi Steel upto LILO point of Devanur (Nanjangud) S/s is already under line clear from 24.10.2021 and almost 35 towers are erected in this bit and in order to complete the project, 04 Nos of Intermediate towers are to be erected and 02 Number of Towers to be replaced from LILO point to Devanur S/s Limits along with replacement of Coyote conductor by Drake by availing LC on 66kV Devenuru to Hemmaragala line as the same is running on common Tower.


**2. 66/11kv Devanur(Nanjangudu) S/S and Suttur S/s : Line Clear on 15.11.2021 , 24.11.2021 and on 30.11.2021**

- As there is no Alternative supply for 66/11kV Devanur S/s and Suttur S/s during line clear period the Power supply for these S/s Station will be interrupted.
- Power Supply for EHT Consumer Like Alambur Water Supply and Suttur Water Supply will be interrupted.
- IPP Generation of M/s Bannari will also be interrupted.
- The existing 66kV supply arrangement from 220kV Chamarajanagar R/s end upto Hemmaragala S/s will be continued.

In continuation, it is stated that during line clear period, the 66/11 kV Devanur and Suttur stations will be completely shut down and **Power Supply will be interrupted** and you are also stated that concerned superintending Engineer(Ele.) has given concurrence for the above said work on **15.11.2021** and on the recommendation made by superintending Engineer(Ele.), O&M Circle, CESC, Mysore concurrence may be accorded.

Hence, I am hereby directed to accord approval to avail line clear of 66KV Devnur (Nanjangudu) & Suttur Substations along with I/c Line on **24.11.2021** between 07:00Hrs to 16:00Hrs and to instruct the concerned Executive Engineer(Ele.,) O & M Division to issue paper notification regarding the Line clear, also to coordinate with KPTCL officers during Line clear period.

Yours faithfully

  
15/11/2021  
General Manager (Tech)  
CESC, Mysuru.

**Copy to:**

1. Superintending Engineer(Ele.,) O &M Circle, Mysuru, CESC.
  2. Executive Engineer(Ele.,) O & M Division, N R Mohalla/Nanjangud, CESC.
  3. Assistant Executive Engineer(DCC), CESC, Mysuru.
  4. PS to MD/TA to DT To place before MD and DT.
- OC/MF