

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ
ನಿಯಮಿತ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ನಿಗಮ ಕಾರ್ಯಾಲಯ,
ಜಾವಿಸನಿನಿ, ಮೈಸೂರು-570017
Telephone No:0821-2417107



**CHAMUNDESHWARI ELECTRICITY
SUPPLY CORPORATION LIMITED**
(A Government of Karnataka Undertaking)
Corporate Office,
CESC, Mysuru-570017
Web Site: www.cescmysore.org.
E-mail ID: gmtech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

CESC/GM(T)/DGM/AGM-2(MIS)/22-23/ 22868-72 Date: 02 FEB 2023

The Chief Engineer (Ele)
O&M Zone, CESC,
Mysuru.

Sir,

Sub: Approval for availing Line clear of 220kv Kadakola-Begur DC Line and 66kv Paniyanhundi-Hemmargala Line for the work of providing LILO arrangement to 66/11kV Karya Sub-Station by stringing 66kv Second circuit for a distance of about 7.301Kms along with one number of 66kV Terminal bay at 66/11kV Karya sub-station in Nanjangudu Taluk, Mysuru District.

Ref: 1. CESC/CEE/SEE(O)/AE-1/2022-23/7168-71 Dtd:25.01.2023.
2. Director(Technical) approval dtd.31.01.2023

Anent to the above subject vide ref (1) it is stated that Chief Engineer(Ele), Transmission Zone, KPTCL, Mysore has requested to arrange concurrence for availing Line Clear on 220kv Kadakola-Begur DC Line and 66kv Paniyanhundi-Hemmargala Line from 04.02.2023 to 05.02.2023 continuously for 2 Days, for the work of providing LILO arrangement to 66/11kV Karya Sub-Station by stringing 66kv Second circuit for a distance of about 7.301Kms along with one number of 66kV Terminal bay at 66/11kV Karya sub-station in Nanjangudu Taluk, Mysuru District.

In continuation it is stated that power supply will be interrupted for the 66kV Karya sub-station and 20MW of IPP generation of M/s Nanj Solar will also be interrupted. Further, it is also stated that Superintending Engineer (Elec.), O&M Circle, CESC, Mysore accorded concurrence for availing line clear for the above said work and you are also recommended for the above line clear.

In view of the above, I am hereby directed to accord approval to avail line clear on 220kv Kadakola-Begur DC Line and 66kv Paniyanhundi-Hemmargala Line from 04.02.2023 to 05.02.2023 and to instruct the concerned Executive Engineer (Ele) O & M Division to issue paper notification regarding line clear duly IP feeders and also to coordinate with KPTCL officers during line clear period.

Yours faithfully


General Manager (Tech)
CESC, Mysuru.

Copy to:

1. The Chief Engineer (Ele), Transmission Zone Mysuru, KPTCL.
2. The Superintending Engineer (Ele), O&M Circle, CESC Mysuru.
3. Executive Engineer(Ele.), O & M Division Nanjangudu.
4. The Assistant Executive Engineer (Ele), DCC, CESC, Mysuru.
5. PS to MD/TA to DT To place before MD and DT.
MF/OC