

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ
ನಿಯಮಿತ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ನಿಗಮ ಕಾರ್ಯಾಲಯ,
ಜಾವಿಸನಿನಿ, ಮೈಸೂರು-570017
Telephone No:0821-2417107



CHAMUNDESHWARI ELECTRICITY
SUPPLY CORPORATION LIMITED
(A Government of Karnataka Undertaking)
Corporate Office,
CESC, Mysuru-570017
Web Site: www.cescmysore.org.
E-mail ID: gmttech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

No: CESC/GM(T)/DGM/AGM-2(MIS)/22-23/

20768-73

Date: 16 JAN 2023

The Chief Engineer (Ele)
O&M Zone, CESC,
Mysuru.

Sir,

Sub: Approval for availing Line clear of existing 66kV Hampapura and Jayapura line which are tapped to Kadakola-Saraguru line - reg.

Ref: 1. CESC/CEE/SEE(O)/AE-1/2022-23/6852-55 Dtd:12.01.2023.

Anent to the above subject vide ref (1) it is stated that Chief Engineer(Ele), Transmission Zone, KPTCL, Mysore has requested to arrange concurrence for availing line clear on existing 66KV Hampapura incoming line which is tapped to 66kV Kadakola-Sarguru line-1 for providing additional 66kV Terminal Bay at existing 66/11KV Hampapura sub station and construction of running additional circuit on existing 66kV Hampapura line for LILO for a distance of 6.5Kms in H.D Kote Taluk, Mysuru district and also line clear is required for stringing of second circuit in the existing DC Towers for a distance of 6.00Kms also, for 66kV Terminal Bay constructions at 66/11kv Jayapura S/s Mysuru Taluk and District. As 66kV Hampapura SC line and 66kV Jayapura SC line are tapped from 66kV Kadakola Saraguru Line, the work can be taken up by removing common jumps at 66/11kV Yarahalli S/s tapping point.

In continuation it is stated that during LC period the power supply to the following sub-station will be affected tapped to 66kV Kadakola-Saraguru line-1 and opening jumps at tapping point of Yarahalli, HD Kote, Antharasanthe stations and Taraka LIS will be interrupted for one(01) hour and it is mentioned that Superintending Engineer (Elec.), O&M Circle, CESC, Mysore has recommended to accord concurrence for availing line clear for the above said work and you are also recommended for the above line clear.

Sl.No	Name of the sub station	Date	Duration of Interruptions
01	Hampapura 66/11kV Sub-station	17.01.23,19.01.23,21.01.23, 23.01.23,25.01.23,27.01.23, 29.01.23 and 31.01.2023	From 10AM to 5 PM All the 11KV Feeders Coming under jurisdiction of Jayapura & Hampapura Substation will be interrupted in this duration.
02	Jayapura 66/11kV Sub-station	21.01.23,23.01.23,25.01.23, 27.01.23,29.01.23 and 31.01.2023	

In view of the above, approval is accord to avail line clear of 66kV Hampapura and Jayapura line which are tapped to Kadakola-Saraguru line for above mentioned dates and to instruct the concerned Executive Engineer (Ele) O & M Divisions to **issue paper notification regarding line clear including IP feeders, to maintain uninterrupted power supply to covid hospitals and also to coordinate with KPTCL officers during line clear period.**

Yours faithfully

General Manager (Tech)
CESC, Mysuru.

Copy to:

1. The Chief Engineer (Ele), Transmission Zone Mysuru, KPTCL.
2. The Superintending Engineer (Ele), O&M Circle, CESC Mysuru.
3. Executive Engineer(Ele.), O & M Division VV Mohalla/Hunsur.
4. The Assistant Executive Engineer (Ele), DCC, CESC, Mysuru.
5. PS to MD/TA to DT To place before MD and DT.

MF/OC