

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ
ನಿಯಮಿತ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ನಿಗಮ ಕಾರ್ಯಾಲಯ,
ಚಾವಿನಿನಿ, ಮೈಸೂರು-570017
Telephone No:0821-2417107



CHAMUNDESHWARI ELECTRICITY
SUPPLY CORPORATION LIMITED
(A Government of Karnataka Undertaking)
Corporate Office,
CESC, Mysuru-570017
Web Site: www.cescmysore.org.
E-mail ID: gmttech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

No: CESC/GM(T)/DGM/AGM-2(MIS)/22-23/

11734-37

Date: 03 SEP 2022

The Chief Engineer (Ele)
O&M Zone, CESC,
Mysuru.

Sir,

Sub: Approval for availing Line clear on 66kV BG Nagar-Hirisave line for carrying out erection of 66kv intermediate tower and stringing 8 span of conductor for making LILO arrangement to existing 66/11kV Kadballi S/s.-Reg.

Ref: 1. CESC/CEE/SEE(O)/AE-1/2022-23/3647-49 Dtd:01.09.2022.
2. Director(Technical) approval note dtd.03.09.2022.¶

Anent to the above subject vide ref (1) it is stated that Chief Engineer(Ele), Transmission Zone, KPTCL, Mysore has requested to arrange concurrence for availing Line clear on 66kV BG Nagar-Hirisave line from 02.09.2022 to 05.09.2022 to carry out the erection of 66kv intermediate tower and stringing 8 span of conductor for making LILO arrangement to existing 66/11kV Kadballi S/s work and the power supply to the following sub-station will be affected.

Sl No	Name of the substation	Dates	Duration of Interruption
1	Kadballi 66/11 KV Substation	04.09.2022 to 07.09.2022	12:00 Hrs to 18:00Hrs

In continuation it is also stated Superintending Engineer (Elec.), O&M Circle, CESC, Mandya and Executive Engineer (Ele), CESC,O&M Division, Nagamangala has accorded Concurrence for availing line clear for the above said work and dates and you are also recommended for line clear.

In view of the above, I am hereby directed to accord approval to avail line clear on 66kV BG Nagar-Hirisave line to carry out the out erection of 66kv intermediate tower and stringing 8 span of conductor for making LILO arrangement to existing 66/11kV Kadballi S/s work from 04.09.2022 to 07.09.2022 and to instruct the concerned Executive Engineer (Ele) O & M Divisions to issue paper notification regarding line clear, to maintain uninterrupted power supply to covid hospitals and also to coordinate with KPTCL officers during line clear period.

Yours faithfully

General Manager (Tech)
CESC, Mysuru.

Copy to:

1. The Chief Engineer (Ele), Transmission Zone Mysuru, KPTCL.
2. The Superintending Engineer (Ele), O&M Circle, CESC Mandya.
3. The Assistant Executive Engineer (Ele), DCC, CESC, Mysuru.
4. PS to MD/TA to DT To place before MD and DT.
MF/OC