

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ
ನಿಯಮಿತ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ನಿಗಮ ಕಾರ್ಯಾಲಯ,
ಜಾವಿಸನಿನಿ, ಮೈಸೂರು-570017
Telephone No:0821-2417107



CHAMUNDESHWARI ELECTRICITY
SUPPLY CORPORATION LIMITED
(A Government of Karnataka Undertaking)
Corporate Office,
CESC, Mysuru-570017
Web Site: www.cescmysore.org.
E-mail ID: gmttech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

No: CESC/GM(T)/DGM/AGM-2(MIS)/22-23/ 18066-70 Date: 09 DEC 2022

The Chief Engineer (Ele)
O&M Zone, CESC,
Mysuru.

Sir,

Sub: Approval for availing Line clear on 66 KV Kushalanagar-Shuntikoppa Line on 11.12.2022.

Ref: 1. CESC/CEE/SEE(O)/AE-1/2022-23/5845-48 Dtd:07.12.2022.
2. Director(Technical) approval note dtd.09.12.2022.

Anent to the above subject vide ref (1) it is stated that Chief Engineer(Ele), Transmission Zone, KPTCL, Mysore has requested to arrange concurrence for availing line clear on 66 KV Kushalanagar-Shuntikoppa Line on Date 11.12.2022 to carry out the work of establishing of 66/33/11 Kv Sub Station at "Hanagalshettyhalli" (Somwarpete) and 66 KV T.B. work at Shuntikoppa S/s.

In continuation it is stated that for the erection of MD+3, 66 KV M/C Tower along with stringing of Coyote conductor to the Terminal bay at 66/11 Kv Sub Station Shuntikoppa, the existing 66 KV Kushalanagar- Shuntikoppa Line shutdown is necessarily required for One (01) day & 3rd Quarterly maintenance work at 66/11 KV sub station Shuntikoppa is also scheduled on 11.12.2022 and by considering the above work as essential you are also recommended for line clear.

In view of the above, I am hereby directed to accord approval to avail line clear on 66 KV Kushalanagar-Shuntikoppa Line on 11.12.2022 from 6:00 am to 6:00 pm and to instruct the concerned Executive Engineer (Ele) O & M Divisions to issue paper notification regarding line clear, to maintain uninterrupted power supply to covid hospitals and also to coordinate with KPTCL officers during line clear period.

Yours faithfully


General Manager (Tech)
CESC, Mysuru.

Copy to:

1. The Chief Engineer (Ele), Transmission Zone Mysuru, KPTCL.
2. The Superintending Engineer (Ele), O&M Circle, CESC Chamarajanagara-Kodagu.
3. Executive Engineer(Ele.), O & M Division Madikeri.
3. The Assistant Executive Engineer (Ele), DCC, CESC, Mysuru.
4. PS to MD/TA to DT To place before MD and DT.
MF/OC