

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು ನಿಗಮ  
ನಿಯಮಿತ  
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)  
ನಿಗಮ ಕಾರ್ಯಾಲಯ,  
ಬಾವಿಸನಿನಿ, ಮೈಸೂರು-570017  
Telephone No:0821-2417107



**CHAMUNDESHWARI ELECTRICITY  
SUPPLY CORPORATION LIMITED**

(A Government of Karnataka Undertaking)  
Corporate Office,  
CESC, Mysuru-570017  
Web Site: [www.cescmysore.org](http://www.cescmysore.org).  
E-mail ID: [gmttech@cescmysore.org](mailto:gmttech@cescmysore.org)

Company Identity Number[CIN]:- U40109KA2004SGC035177

No: CESC/GM(T)/DGM/AGM-2(MIS)/22-23/ 12233-36 Date: 09 SEP 2022

The Chief Engineer (Ele)  
O&M Zone, CESC,  
Mysuru.

Sir,

**Sub:** Approval for availing Line clear on 66kV TK halli –Mandya DC line on 11.09.2022 and 12.09.2022 from 10 AM to 6PM for shifting of 66kV 2 nd circuit on existing 66kV S/C on DC tower from tap point of existing 66kV T.H HALLi-Mandya M1 Scline for a distance of about 0.56 kM with LILO arrangement at 66/11kV S/s at Kolkoranadoddi along with modification works in Mandya Taluk & District.–Reg.

**Ref:** 1. CESC/CEE/SEE(O)/AE-1/2022-23/3320-22 Dtd:08.09.2022.  
2. Director(Technical) approval note dtd.09.09.2022.

\*\*\*\*\*

Anent to the above subject vide ref (1) it is stated that Chief Engineer(Ele), Transmission Zone, KPTCL, Mysore has requested vide reference to arrange concurrence for availing Line clear on 66kV TK halli –Mandya DC line on 11.09.2022 and 12.09.2022 to carry out for shifting of 66kV 2 nd circuit on existing 66kV S/C on DC tower from tap point of existing 66kV T.H HALLi-Mandya M1 Scline for a distance of about 0.56 kM with LILO arrangement at 66/11kV S/s at Kolkoranadoddi along with modification works in Mandya Taluk & District and the power supply to the following sub-station will be affected.

| Sl No | Name of the substation/Line           | Dates                     | Duration of Interruptions  |
|-------|---------------------------------------|---------------------------|--|
| 1     | Kolkoranadoddi<br>66/11 KV Substation | 11.09.2022<br>&12.09.2022 | 10:00 Hrs to 18:00Hrs<br>(Power supply to NJY feeders of<br>Kolkoranadoddi station will be<br>interrupted) |

In continuation it is also stated Superintending Engineer (Elec.), O&M Circle, CESC, Mandya has accorded Concurrence for availing line clear for the above said work and dates and you are also recommended for line clear.

In view of the above, I am hereby directed to accord approval to avail line clear on on 66kV TK halli –Mandya DC line on 11.09.2022 and 12.09.2022 to carry out for shifting of 66kV 2 nd circuit on existing 66kV S/C on DC tower from tap point of existing 66kV T.H HALLi-Mandya M1 Scline for a distance of about 0.56 kM with LILO arrangement at 66/11kV S/s at Kolkoranadoddi along with modification works in Mandya Taluk & District and to instruct the concerned Executive Engineer (Ele) O & M Divisions to issue paper notification regarding line clear, to maintain uninterrupted power supply to covid hospitals and also to coordinate with KPTCL officers during line clear period.

Yours faithfully

  
General Manager (Tech)  
CESC, Mysuru.

**Copy to:**

1. The Chief Engineer (Ele), Transmission Zone Mysuru, KPTCL.
2. The Superintending Engineer (Ele), O&M Circle, CESC Mandya.
3. The Assistant Executive Engineer (Ele), DCC, CESC, Mysuru.
4. PS to MD/TA to DT To place before MD and DT.

MF/OC