

ಚಾಮುಂಡೇಶ್ವರಿ ವಿದ್ಯುತ್ ಸರಬರಾಜು
ನಿಗಮ ನಿಯಮಿತ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ನಿಗಮ ಕಾರ್ಯಾಲಯ,
ಜಾವಿಸನಿ, ಮೈಸೂರು-570017
Telephone No:0821-2417107



**CHAMUNDESHWARI ELECTRICITY
SUPPLY CORPORATION LIMITED**

(A Government of Karnataka Undertaking)

Corporate Office,
CESC, Mysuru-570017

Web Site: www.cescmysore.org.

E-mail ID: gmttech@cescmysore.org

Company Identity Number[CIN]:- U40109KA2004SGC035177

No: CESC/GMT/DGM(MIS)/AGM-2/21-22/ 15351-55

Date: 10 DEC 2021

Chief Engineer (Ele.,)
CESC, O&M Zone
Mysuru.

Sir,

Sub: Approval for availing line clear for replacement of 1x12.5MVA, 66/11kv power transformer by 1x20 MVA, 66/11 kv power transformer at 66/11kv Thandya substation in Nanjangud Taluk-Reg

Ref: 1.Letter No.CESC/CEE/SEE(O)/AE/2021-22/4622-24 dated:07.12.2021 of
Chief Engineer(Ele), O&M Zone, CESC Mysore.
2. Director(Technical) approval note dtd.09.12.2021.

Anent to the above subject, vide your letter under reference(1), it is stated that Chief Engineer(Ele), Transmission Zone, KPTCL, Mysore has requested to arrange concurrence for availing line clear for replacement of 1x12.5 MVA, 66/11 kv power transformer by 1x20 MVA, 66/11 kv power transformer at 66/11kv Thandya substation on 12.12.2021 from 11.00Hrs to 17:00Hrs.

In continuation, it is stated that Superintending Engineer (Elec.), O&M Circle, CESC, Mysore has accorded concurrence for availing line clear and on the recommendation made by Superintending Engineer(Ele.), O&M Circle, CESC, Mysore concurrence may be accorded.

Hence, I am hereby directed to accord approval to avail line clear of 66/11 KV Thandya Sub-Station on **12.12.2021 from 11.00Hrs to 16:00Hrs** and to instruct the concerned Executive Engineer(Ele.,) O & M Division to issue paper notification regarding the Line clear, to maintain uninterrupted power supply to Hospitals & also to coordinate with KPTCL officers during Line clear period and to carry out maintenance of 11kV feeders on the same day.

Yours faithfully


10/12/2021
General Manager (Tech)
CESC, Mysuru.

Copy to:

1. Chief Engineer(Ele.,), Transmission Zone, KPTCL, Mysuru for information.
2. Superintending Engineer(Ele.,) O &M Circle, Mysore, CESC.
3. Executive Engineer(Ele.,) O & M Division, Nanjangud, CESC.
4. Assistant Executive Engineer(DCC), CESC, Mysuru.
5. PS to MD/TA to DT To place before MD and DT.

OC/MF

ನೋಂದಾಯಿತ ಕಛೇರಿ: ನಿಗಮ ಕಾರ್ಯಾಲಯ, ನಂ. 29, ವಿಜಯನಗರ, 2ನೇ ಹಂತ, ಹಿಂಕಲ್, ಮೈಸೂರು - 570017

Registered Office: Corporate Office, # 29, Vijayanagara, 2nd Stage, Hinkal, Mysuru-570017